

Environmental Monitoring Service

Testing and research laboratory for water, soil and food products

Aurobrindavan, Auroville, T.N., India - 605101

Phone: 91-0413-2677096/2677070

E-mail: ems@auroville.org.in

Test Report

Customer name: Affordable Water
Solutions
Nature of sample: Treated water
by AuroPure

Sample received: 4/10/16
Analysis completed: 4 /10/16
Sample collected: By lab person
Lab ID: 149

Objective:

To examine the efficiency of water treatment system AuroPure for Fluoride removal.

Procedure: Tap water was spiked with fluoride 5 ppm and 15 ppm and treated by AuroPure system.


Method of testing:

Fluoride analyzed by Ion Selective Method.

Results are tabulated below.

Parameters	Initial concentration, mg/L	Concentration after treatment mg/L	Removal rate after treatment %
Fluoride (as F)	5	0.3	94.0
Fluoride (as F)	15	1.4	90.7

Analyst



Lab executive

